



EXIT SIGN / EMERGENCY LIGHTING TEST LOG

YEAR: _____

BUSINESS NAME: _____

TEST MONTH	ACTUAL TEST DATE	INDICATE TESTING DURATION (30 sec or 1 hr)	# OF LIGHT UNITS OPERATIONAL	# OF LIGHT UNITS DEFECTIVE	LOCATION OF DEFECTIVE LIGHT UNITS	DATE REPAIRED	COMMENTS	PRINT NAME OF TESTER
JAN								
FEB								
MAR								
APR								
MAY								
JUNE								
JULY								
AUG								
SEPT								
OCT								
NOV								
DEC								

RECORDS: A written record of tests and maintenance shall be kept of premises at all times.

NFPA 1 CODE: 14.13.2.1.2 Testing of required emergency lighting systems

shall be permitted to be conducted as follows:

(1) Self-testing/self-diagnostic battery-operated emergency lighting equipment shall be provided.

(2) Not less than once every 30 days, self-testing/self-diagnostic battery-operated emergency lighting equipment shall automatically perform a test with a duration of a minimum of 30 seconds and a diagnostic routine.

(3) Self-testing/self-diagnostic battery-operated emergency lighting equipment shall indicate failures by a status indicator.

(4) A visual inspection shall be performed at intervals not exceeding 30 days.

(5) Functional testing shall be conducted annually for a minimum of 1½ hours.

(6) Self-testing/self-diagnostic battery-operated emergency lighting equipment shall be fully operational for the duration of the 1½ hour test.

(7) Written records of visual inspections and tests shall be kept by the owner for inspection by the AHJ.